

Fairbanks Road Elementary School - Churchville-Chili CSD
Lead Test Results 2021

	A	B	C	D	E	F
1	Lead Testing 2021					
2	Lab I D #	Locations	Collection Date	Description	Result	Action
3	012104519-0001	RM 120	4/24/2021	FAUCET	0.00	N/A
4	012104519-0002	RM 303	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
5	012104519-0003	RM 308	4/24/2021	BUBBLER	7.14	N/A
6	012104519-0004	RM 308	4/24/2021	FAUCET	4.88	N/A
7	012104519-0005	RM 310	4/24/2021	FAUCET	5.97	N/A
8	012104519-0006	RM 310	4/24/2021	BUBBLER	7.42	N/A
9	012104519-0007	RM 312	4/24/2021	FAUCET	1.83	N/A
10	012104519-0008	RM 312	4/24/2021	BUBBLER	3.58	N/A
11	012104519-0009	RM 314	4/24/2021	FAUCET	0.00	N/A
12	012104519-0010	RM 314	4/24/2021	BUBBLER	0.00	N/A
13	012104519-0011	RM 316	4/24/2021	FAUCET	0.00	N/A
14	012104519-0012	RM 316	4/24/2021	BUBBLER	0.00	N/A
15	012104519-0013	RM 317	4/24/2021	FAUCET	1.36	N/A
16	012104519-0014	RM 317	4/24/2021	BUBBLER	1.17	N/A
17	012104519-0015	RM 315	4/24/2021	FAUCET	0.00	N/A
18	012104519-0016	RM 315	4/24/2021	BUBBLER	0.00	N/A
19	012104519-0017	RM 313	4/24/2021	FAUCET	3.66	N/A
20	012104519-0018	RM 313	4/24/2021	BUBBLER	4.97	N/A
21	012104519-0019	RM 311	4/24/2021	FAUCET	18.80	OUT OF SERVICE
22	012104519-0020	RM 311	4/24/2021	BUBBLER	2.97	N/A
23	012104519-0021	RM 309	4/24/2021	FAUCET	3.00	N/A
24	012104519-0022	RM 309	4/24/2021	BUBBLER	6.79	N/A
25	012104519-0023	RM 307	4/24/2021	FAUCET	7.48	N/A

Fairbanks Road Elementary School - Churchville-Chili CSD
Lead Test Results 2021

	A	B	C	D	E	F
26	012104519-0024	RM 307	4/24/2021	BUBBLER	5.05	N/A
27	012104519-0025	RM 305	4/24/2021	FAUCET	13.00	N/A
28	012104519-0026	RM 305	4/24/2021	BUBBLER	14.30	N/A
29	012104519-0027	RM 303	4/24/2021	FAUCET	2.38	N/A
30	012104519-0028	RM 303	4/24/2021	BUBBLER	4.13	N/A
31	012104519-0029	RM 301	4/24/2021	FAUCET	12.70	N/A
32	012104519-0030	RM 301	4/24/2021	BUBBLER	34.40	OUT OF SERVICE
33	012104519-0031	KITCHEN	4/24/2021	PREP L	2.14	N/A
34	012104519-0032	KITCHEN	4/24/2021	PREP R	3.06	N/A
35	012104519-0033	RM 202	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
36	012104519-0034	RM 204	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
37	012104519-0035	RM 207	4/24/2021	FAUCET	16.80	OUT OF SERVICE
38	012104519-0036	RM 209	4/24/2021	FAUCET	4.67	N/A
39	012104519-0037	RM 209	4/24/2021	BUBBLER	9.44	N/A
40	012104519-0038	RM 211	4/24/2021	FAUCET BUBBLER	4.12	N/A
41	012104519-0039	RM 211	4/24/2021	FF	1.69	N/A
42	012104519-0040	RM 213	4/24/2021	FAUCET	3.04	N/A
43	012104519-0041	RM 213	4/24/2021	BUBBLER	3.21	N/A
44	012104519-0042	RM 214	4/24/2021	FAUCET	3.32	N/A
45	012104519-0043	RM 214	4/24/2021	BUBBLER	4.38	N/A
46	012104519-0044	RM 212	4/24/2021	FAUCET	6.97	N/A
47	012104519-0045	RM 212	4/24/2021	BUBBLER	4.99	N/A
48	012104519-0046	RM 210	4/24/2021	FAUCET	1.87	N/A
49	012104519-0047	RM 210	4/24/2021	BUBBLER	0.00	N/A
50	012104519-0048	RM 208	4/24/2021	FAUCET	2.01	N/A

Fairbanks Road Elementary School - Churchville-Chili CSD
Lead Test Results 2021

	A	B	C	D	E	F
51	012104519-0049	RM 208	4/24/2021	BUBBLER	1.12	N/A
52	012104519-0050	RM 008	4/24/2021	FAUCET	1.21	N/A
53	012104519-0051	RM 008	4/24/2021	BUBBLER	1.17	N/A
54	012104519-0052	RM 010	4/24/2021	FAUCET	2.78	N/A
55	012104519-0053	RM 010	4/24/2021	BUBBLER	2.57	N/A
56	012104519-0054	RM 012	4/24/2021	FAUCET	4.35	N/A
57	012104519-0055	RM 012	4/24/2021	BUBBLER	6.08	N/A
58	012104519-0056	RM 014	4/24/2021	FAUCET	7.83	N/A
59	012104519-0057	RM 014	4/24/2021	BUBBLER	2.19	N/A
60	012104519-0058	RM 015	4/24/2021	FAUCET	5.46	N/A
61	012104519-0059	RM 015	4/24/2021	BUBBLER	4.46	N/A
62	012104519-0060	RM 013	4/24/2021	FAUCET	1.82	N/A
63	012104519-0061	RM 013	4/24/2021	BUBBLER	2.35	N/A
64	012104519-0062	RM 011	4/24/2021	FAUCET	3.21	N/A
65	012104519-0063	RM 011	4/24/2021	BUBBLER	2.68	N/A
66	012104519-0064	RM 009	4/24/2021	FAUCET	1.63	N/A
67	012104519-0065	RM 009	4/24/2021	BUBBLER	2.20	N/A
68	012104519-0066	RM 105	4/24/2021	FAUCET	0.00	N/A
69	012104519-0067	RM 105	4/24/2021	AF	0.00	N/A
70	012104519-0068	RM 109	4/24/2021	FAUCET	6.61	N/A
71	012104519-0069	RM 113	4/24/2021	FAUCET	19.10	OUT OF SERVICE
72	012104519-0070	RM 113	4/24/2021	BUBBLER	22.20	OUT OF SERVICE
73	012104519-0071	RM 115	4/24/2021	FAUCET	6.36	N/A
74	012104519-0072	RM 115	4/24/2021	BUBBLER	4.94	N/A
75	012104519-0073	RM 117	4/24/2021	FAUCET	3.10	N/A

Fairbanks Road Elementary School - Churchville-Chili CSD
Lead Test Results 2021

	A	B	C	D	E	F
76	012104519-0074	RM 117	4/24/2021	BUBBLER	28.80	OUT OF SERVICE
77	012104519-0075	RM 116	4/24/2021	FAUCET	3.42	N/A
78	012104519-0076	RM 116	4/24/2021	BUBBLER	7.63	N/A
79	012104519-0077	RM 118	4/24/2021	FAUCET	1.81	N/A
80	012104519-0078	RM 118	4/24/2021	BUBBLER	1.15	N/A
81	012104519-0079	RM 114	4/24/2021	FAUCET	2.30	N/A
82	012104519-0080	RM 114	4/24/2021	BUBBLER	1.15	N/A
83	012104519-0081	RM 106	4/24/2021	FAUCET	1.09	N/A
84	012104519-0082	RM 102	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
85						
86						
87						
88						
89						
90						
91						
92						
93						
94						
95						
96						
97						