

Main Campus - Churchville-Chili CSD

Lead Test Results 2021

Lead Testing 2021					
Location	Main Campus				
Lab I D #	Locations	Collection Date	Description	Result	Action
Senior High School					N/A
012104454-0001	RM 1029	4/24/2021	FAUCET	0.00	N/A
012104454-0002	RM 1034	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0003	RM 1047	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0004	RM 1049	4/24/2021	FAUCET	3.14	N/A
012104454-0005	CAFÉ	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0006	KITCHEN	4/24/2021	ICE	0.00	N/A
012104454-0007	KITCHEN	4/24/2021	PREP FAUCET	23.70	OUT OF SERVICE
012104454-0008	KITCHEN	4/24/2021	FAUCET LEFT	14.10	N/A
012104454-0009	KITCHEN	4/24/2021	FAUCET RIGHT	14.70	N/A
012104454-0010	RM 1223	4/24/2021	FAUCET	10.40	N/A
012104454-0011	RM 1324	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0012	RM 1344	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0013	RM 1406	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0014	RM 1405	4/24/2021	FAUCET	0.00	N/A
012104454-0015	TRA	4/24/2021	FAUCET	0.00	N/A
012104454-0016	RM 1603	4/24/2021	FAUCET	0.00	N/A
012104454-0017	RM 1601	4/24/2021	FAUCET	1.04	N/A
012104454-0018	GYM B	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0019	GYM A	4/24/2021	GWATER COOLER BOTTLE	0.00	N/A
012104454-0020	GYM A	4/24/2021	BWATER COOLER BOTTLE	0.00	N/A
012104454-0030	RM 1155	4/24/2021	WATER COOLER BOTTLE	0.00	N/A

Main Campus - Churchville-Chili CSD

Lead Test Results 2021

012104454-0065	RM 1111	4/24/2021	FAUCET LEFT	1.07	N/A
012104454-0066	RM 1111	4/24/2021	FAUCET RIGHT	1.34	N/A
012104454-0067	RM 1111	4/24/2021	FAUCET MIDDLE	0.00	N/A
012104454-0068	RM 1114	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0069	RM 1013	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0070	RM 1013	4/24/2021	FAUCET RIGHT	0.00	N/A
012104454-0074	RM 1013	4/24/2021	FAUCET LEFT	1.00	N/A
012104454-0076	RM 1222	4/24/2021	FAUCET A	2.05	N/A
012104454-0077	RM 1222	4/24/2021	FAUCET B	1.63	N/A
012104454-0078	RM 1222	4/24/2021	FAUCET C	4.40	N/A
012104454-0079	RM 1222	4/24/2021	FAUCET D	3.28	N/A
012104454-0080	RM 1222	4/24/2021	FAUCET E	4.12	N/A
012104454-0081	RM 1222	4/24/2021	FAUCET F	3.38	N/A
MIDDLE SCHOOL SOUTH					
Lab I D #	Locations	Collection Date	Description	Result	Action
012104454-0021	KITCHEN	4/24/2021	ICE	0	
012104454-0022	KITCHEN	4/24/2021	PREP LEFT	4.48	N/A
012104454-0023	KITCHEN	4/24/2021	PREP RIGHT	1.71	N/A
012104454-0024	A	4/24/2021	ICE	0	N/A
012104454-0025	CAFÉ	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0026	RM 2201	4/24/2021	FAUCET	0	N/A
012104454-0027	RM 2206	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0028	RM 2102	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0029	RM 2205	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0031	EXIT 12	4/24/2021	WATER COOLER BOTTLE	0	N/A

Main Campus - Churchville-Chili CSD

Lead Test Results 2021

012104454-0032	NURSE	4/24/2021	FAUCET	6.88	N/A
012104454-0033	RM 2606	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0034	RM 2607	4/24/2021	FAUCET BUBBLER	1.63	N/A
012104454-0035	RM 2607	4/24/2021	FAUCET F	1.82	N/A
012104454-0036	RM 2603	4/24/2021	FAUCET F	3.18	N/A
012104454-0037	RM 2603	4/24/2021	FAUCET BUBBLER	2.69	N/A
012104454-0038	RM 2604	4/24/2021	OFAUCET	6.22	N/A
012104454-0039	RM 2134	4/24/2021	WATER COOLER BOTTLE	0	N/A
012104454-0075	RM 2206	4/24/2021	FAUCET	24.7	OUT OF SERVICE
MIDDLE SCHOOL NORTH					
Lab I D #	Locations	Collection Date	Description	Result	Action
012104454-0040	RM 3301	4/24/2021	FAUCET LEFT	0.00	N/A
012104454-0041	RM 3301	4/24/2021	FAUCET RIGHT	1.13	N/A
012104454-0042	RM 3302	4/24/2021	FAUCET	1.68	N/A
012104454-0043	RM 3308	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0044	RM 3314	4/24/2021	FAUCET	5.15	N/A
012104454-0045	RM 3318	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0046	RM 3109	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0047	RM 3125	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0048	LIBRARY	4/24/2021	FAUCET	1.58	N/A
012104454-0049	RM 3124	4/24/2021	FAUCET	1.09	N/A
012104454-0050	RM 3133	4/24/2021	FAUCET	0.00	N/A
012104454-0051	RM 3804	4/24/2021	FAUCET	1.52	N/A
012104454-0052	RM 3812	4/24/2021	FAUCET	0.00	N/A
012104454-0053	CO	4/24/2021	FAUCET	0.00	N/A

Main Campus - Churchville-Chili CSD

Lead Test Results 2021

012104454-0054	RM 3520	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0055	CAFÉ	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0056	KITCHEN	4/24/2021	PREP LEFT	10.00	N/A
012104454-0057	KITCHEN	4/24/2021	PREP MIDDLE	7.27	N/A
012104454-0058	KITCHEN	4/24/2021	PREP RIGHT	18.30	OUT OF SERVICE
012104454-0059	KITCHEN	4/24/2021	ICE	0.00	N/A
012104454-0060	GYM C	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0061	GYM D	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0062	EXIT 37	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0063	EXIT 15	4/24/2021	WATER COOLER BOTTLE	0.00	N/A
012104454-0064	LIBRARY	4/24/2021	WATER COOLER BOTTLE S	0.00	N/A
012104454-0071	RM 3302	4/24/2021	FAUCET RIGHT	1.48	N/A
012104454-0072	RM 3302	4/24/2021	FAUCET MIDDLE	1.97	N/A
012104454-0073	BL GYM D	4/24/2021	WATER COOLER BOTTLE	0.00	N/A